

Kent Academic Repository

Full text document (pdf)

Citation for published version

Graves, Hilary and Watkins, Richard and Westbury, P and Littlefair, P (2001) Cooling Buildings in London: Overcoming the Heat Island. BRE Report . BREPress, UK, 36 pp. ISBN 1-86081-526-X.

DOI

Link to record in KAR

<https://kar.kent.ac.uk/52519/>

Document Version

UNSPECIFIED

Copyright & reuse

Content in the Kent Academic Repository is made available for research purposes. Unless otherwise stated all content is protected by copyright and in the absence of an open licence (eg Creative Commons), permissions for further reuse of content should be sought from the publisher, author or other copyright holder.

Versions of research

The version in the Kent Academic Repository may differ from the final published version.

Users are advised to check <http://kar.kent.ac.uk> for the status of the paper. **Users should always cite the published version of record.**

Enquiries

For any further enquiries regarding the licence status of this document, please contact:

researchsupport@kent.ac.uk

If you believe this document infringes copyright then please contact the KAR admin team with the take-down information provided at <http://kar.kent.ac.uk/contact.html>

Cooling buildings in London

Overcoming the heat island

Hilary Graves, Richard Watkins,
Philippa Westbury and Paul Littlefair

BRE

constructing the future



Cooling buildings in London: overcoming the heat island

Hilary Graves, Richard Watkins,
Philippa Westbury and Paul Littlefair

BRE Centre for Environmental Engineering



constructing the future



Prices for all available
BRE publications can
be obtained from:
CRC Ltd
151 Rosebery Avenue
London, EC1R 4GB
Tel: 020 7505 6622
Fax: 020 7505 6606
email:
crc@construct.emap.co.uk

BR 431
ISBN 1 86081 526 X
© Copyright BRE 2001
First published 2001

BRE is committed to providing impartial and authoritative information on all aspects of the built environment for clients, designers, contractors, engineers, manufacturers, occupants, etc. We make every effort to ensure the accuracy and quality of information and guidance when it is first published. However, we can take no responsibility for the subsequent use of this information, nor for any errors or omissions it may contain.

Published by
Construction Research
Communications Ltd
by permission of
Building Research
Establishment Ltd

Requests to copy any
part of this publication
should be made to:
CRC Ltd
Building Research
Establishment
Bucknalls Lane
Watford, WD25 9XX

BRE material is also published quarterly on CD

Each CD contains BRE material published in the current year, including reports, specialist reports, and the Professional Development publications: Digests, Good Building Guides, Good Repair Guides and Information Papers.

The CD collection gives you the opportunity to build a comprehensive library of BRE material at a fraction of the cost of printed copies.

As a subscriber you also benefit from a 25% discount on other BRE titles.

**For more information contact:
CRC Customer Services on 020 7505 6622**

Construction Research Communications

CRC supplies a wide range of building and construction related information products from BRE and other highly respected organisations.

Contact:

post: CRC Ltd
151 Rosebery Avenue
London, EC1R 4GB

fax: 020 7505 6606
phone: 020 7505 6622
email: crc@construct.emap.co.uk
website: www.constructionplus.co.uk

Contents

	Acknowledgements	iv
	Introduction	1
Chapter 1	London's heat island	2
	Impact of building design on the urban heat island and peak cooling load	2
	Measurements of London temperatures	4
	Effect of heat island on cooling	9
	Local variations in temperature	11
Chapter 2	Data for calculating the impact of temperature on peak cooling loads	16
Chapter 3	Reducing the effect of the heat island	18
	Building layout	18
	Landscaping and vegetation	20
	Albedo	22
	Solar shading	23
	Cooling alternatives	24
	Location of inlets and outlets	25
	Reducing casual gains	26
	Conclusion	27
	References	28
Appendix	Assumptions associated with modelling of cooling load	29
	A1 Construction elements	29
	A2 Internal gains	30
	A3 Scheduling	30
	A4 Choice of model	31
	A5 Weather data	31
	A6 Primary energy used for cooling	32
Diskette	Temperature differences between London and Bracknell	Inside back cover

Acknowledgements

The work described in this guide was funded by the Construction Directorate of the Department of the Environment, Transport and the Regions under its Framework Programme.

We would like to thank the following staff who assisted in the development of this guide. David Taylor, Chris Tootell and Agnes Sheridan helped to collect the temperature data from the sites in London. Agnes Sheridan also derived the temperature differences for the diskette; Liam Roche wrote the user interface for this. Michael Chandler helped with data analysis and collection of the data from near the River Thames.

Maria Kolokotroni (Brunel University), John Palmer and Earle Perera provided advice and guidance.

This work would not have been possible without the considerable help of the 33 local authorities in London and surrounding areas. Numerous landowners have also been extremely obliging in giving permission for measurement stations to be set up on their land.

Introduction

BRE has been developing guidance for building designers on low-energy design solutions which maximise the application of solar access and passive cooling strategies in the urban environment. This guide and the design tool it includes have been produced to enable the construction industry to move towards reducing the impact of the urban heat island on peak cooling-energy demand in buildings.

Central areas of London can be significantly warmer than the surrounding areas, a phenomenon known as the heat island effect. These increased temperatures have an important impact on the cooling loads in buildings. Average cooling demand in a central London site is more than that at a rural site, and the efficiency of air-conditioning plant is decreased at higher temperatures. So the use of rural temperature data to calculate cooling loads can result in significant underestimates.

This guide presents the results of a unique long-term monitoring experiment to measure air temperatures at 80 sites spread around London. Summertime temperatures from some of the sites were then used in a model for a typical office building. The resulting design tool on the diskette included with this guide allows the designer to modify temperature data from Bracknell (the reference site for temperature data on pages 2–71 of CIBSE Guide A^[1]) for the calculation of peak summertime cooling loads at 80 different locations in London.

The guide also outlines a range of techniques to reduce or even eliminate the effects of the heat island by careful design of the building and its surroundings, including:

- Alternative cooling strategies such as natural ventilation, night cooling, mixed mode
- Building layout to encourage wind flow and ventilation
- Landscaping and vegetation using trees and green areas, vines and other plants on walls
- Water features
- Surfaces with high albedo, to reduce heat build up
- Solar shading
- Reducing casual gains; avoiding unnecessary cooling caused by inefficient equipment and lighting

Chapter 1 London's heat island

Impact of building design on the urban heat island and peak cooling load

Properties of urban climate influenced by urban planning and building design

Cities have their own urban climates. The presence of buildings, and the activities taking place in the city, can change:

- Air and radiant temperatures
- Wind velocity and turbulence intensity (or 'gustiness')
- Humidity
- Air pollution

Air temperature has the largest impact on a building's peak cooling load, with humidity having a secondary effect. Wind velocity and turbulence, and air pollution, additionally influence the feasibility of cooling using natural ventilation rather than mechanical cooling. Air pollution also influences local climate, since absorption and scattering of incoming solar radiation by air pollutants affects the overall radiation balance for a city. Figure 1 illustrates the accumulation of a layer of pollutants in still winter conditions, producing a haze over the city of London.

Effective building design can have a beneficial effect on the urban climate and contribute towards reducing the intensity of the urban heat island, as well as directly reducing the peak cooling load of a building.



Figure 1 Polluted layer over the city of London

Urban heat island intensity

The urban heat island is described by its 'intensity', which is defined as the peak difference between urban and rural temperatures. In London, the urban heat island is most intense at night-time rather than during the day, and in calm, clear conditions.

Microscale and macroscale effects of building design and urban planning

Microscale effects

The design of individual buildings and small groups of buildings can influence the air temperature, wind characteristics and other climate features close to the building, ie the microclimate. Local variations in microclimate around the building or development can occur.

Macroscale effects

Each of the microclimates generated by small-scale features of the urban landscape (individual buildings and groups of buildings) will combine together to influence the larger-scale climate or urban heat island. For example, small-scale heat islands within the city will contribute to raising the overall city temperature. In addition, urban-scale factors, for example the size of a city and the density of the built-up area, will influence the intensity of the urban heat island.

Main factors contributing to the urban heat island

The main factors contributing to the urban heat island include:

- The increase in overall net radiation gain relative to a rural area, caused by the lower rate of radiant cooling during the night
- The storage of solar energy during the day by building materials, particularly those with dark surfaces. This is released at night
- Anthropogenic heat sources (eg transportation, heating and air conditioning, cooking and other industrial processes)
- The reduction in evaporation from soil and vegetation
- Decrease in convective heat loss from buildings to the air due to reduction in wind speed