

Kent Academic Repository

Full text document (pdf)

Citation for published version

Farias Moguel, O and Clements, A G and Szuhánszki, J and Ingham, D B and Ma, L and Hossain, M M and Lu, Gang and Yan, Yong and Pourkashanian, M (2016) Large eddy simulation of a coal flame: estimation of the flicker frequency under air and oxy-fuel conditions. In: 11th European Conference on Coal Research and its Applications, 5-7 Sept 2016, the University of Sheffield,

DOI

Link to record in KAR

<http://kar.kent.ac.uk/57979/>

Document Version

Presentation

Copyright & reuse

Content in the Kent Academic Repository is made available for research purposes. Unless otherwise stated all content is protected by copyright and in the absence of an open licence (eg Creative Commons), permissions for further reuse of content should be sought from the publisher, author or other copyright holder.

Versions of research

The version in the Kent Academic Repository may differ from the final published version.

Users are advised to check <http://kar.kent.ac.uk> for the status of the paper. **Users should always cite the published version of record.**

Enquiries

For any further enquiries regarding the licence status of this document, please contact:

researchsupport@kent.ac.uk

If you believe this document infringes copyright then please contact the KAR admin team with the take-down information provided at <http://kar.kent.ac.uk/contact.html>

Large eddy simulation of a coal flame: estimation of the flicker frequency under air and oxy-fuel conditions

*Farias Moguel, O.^a, Clements, A. G.^a, Szuhánszki, J.^a, Ingham, D. B.^a, Ma, L.^a, Bai, X.^b, Hossain, M. M.^b, Lu, G.^b, Yan, Y.^b, Pourkashanian, M.^a

^aEnergy 2050, Faculty of Engineering,
The University of Sheffield, Sheffield, UK, S10 2JT

^bSchool of Engineering and Digital Arts,
The University of Kent, Canterbury, UK, CT2 7NT

Abstract for oral presentation:

Fossil fuel combustion, such as coal combustion, currently meets the majority of the global energy demand; however, the process also produces a significant proportion of the worldwide CO₂ greenhouse gas emissions. Further improvement in the efficiency and control of the combustion process is needed, as well as the implementation of novel technologies such as carbon capture and storage (CCS). Oxy-fuel combustion is a very promising CCS technology, where the air in the combustion process is replaced with a mixture of recycled flue gas and oxygen producing a high CO₂ outflow that can effectively be processed or stored. The adjustment of the combustion environment within the boiler resulting from the high CO₂ concentration will modify the flame characteristics. It is therefore important to evaluate properly the changes of the flame that occur with different flue gas recycle schemes.

A coal flame is often characterised by its physical parameters, such as the flame size, shape, brightness and temperature, and it can be considered as a stable flame by the presence of ignition and the propagation of the flame. The oscillatory behaviour of a flame can be quantified by the flicker frequency obtained after the instantaneous variations of the flame parameters, and is used as a reference for flame stability.

Computational Fluid Dynamics (CFD) is widely used to model coal combustion. This work compares the estimated flicker frequency taken from CFD calculations against measurements undertaken at the experimental facilities of the UKCCSRC Pilot-scale Advanced Capture Technology (PACT) located in South Yorkshire, UK. The 250 kW combustion test facility consists of a down-fired, refractory lined cylindrical furnace, which is 4 m in height with a 0.9 m internal diameter. The furnace is fitted with a scaled version of a commercially available Doosan Babcock low-NO_x burner.

The flame physical parameters are approximated from performing a Large Eddy Simulation (LES) using the CFD code ANSYS FLUENT v15. The flicker frequency obtained from the CFD approach is compared against the experimentally measured value from a 2D flame imaging system. A series of oxy-fuel cases are then examined in the same fashion in order to assess their flame stability and the boiler operational limit. The flicker frequency trend obtained from the computations and measurements helps to determine the dynamic response of the flame for different combustion environments, and the results will be applicable in determining the optimal recycle ratio applied in future oxy-fuel systems.

Keywords: LES, flame, flicker frequency, oxy-fuel, coal combustion, CFD, digital imaging.

Acknowledgements: The authors would like to acknowledge EPSRC for funding this work.

**Corresponding author:*

[e-mail: ofariasmoguel1@sheffield.ac.uk](mailto:ofariasmoguel1@sheffield.ac.uk)