



Kent Academic Repository

Hossain, Md. Moinul, Cugley, James, Lu, Gang, Caesar, Steve, Cornwell, Steve, Riley, Gerry and Yan, Yong (2018) *Burner Condition Monitoring based on Flame Imaging and Data Fusion Techniques*. In: 12th ECCRIA - The European Conference on Fuel and Energy Research and its Applications. . TFERF- The Fuel and Energy Research Forum (Unpublished)

Downloaded from

<https://kar.kent.ac.uk/69032/> The University of Kent's Academic Repository KAR

The version of record is available from

This document version

Supplemental Material

DOI for this version

Licence for this version

UNSPECIFIED

Additional information

Versions of research works

Versions of Record

If this version is the version of record, it is the same as the published version available on the publisher's web site. Cite as the published version.

Author Accepted Manuscripts

If this document is identified as the Author Accepted Manuscript it is the version after peer review but before type setting, copy editing or publisher branding. Cite as Surname, Initial. (Year) 'Title of article'. To be published in *Title of Journal*, Volume and issue numbers [peer-reviewed accepted version]. Available at: DOI or URL (Accessed: date).

Enquiries

If you have questions about this document contact ResearchSupport@kent.ac.uk. Please include the URL of the record in KAR. If you believe that your, or a third party's rights have been compromised through this document please see our [Take Down policy](https://www.kent.ac.uk/guides/kar-the-kent-academic-repository#policies) (available from <https://www.kent.ac.uk/guides/kar-the-kent-academic-repository#policies>).

Burner Condition Monitoring based on Flame Imaging and Data Fusion Techniques

*M. M. Hossain¹, J. Cugley¹, G. Lu¹, S. Caesar², S. Cornwell², G. Riley², Y. Yan¹

¹ School of Engineering and Digital Arts, University of Kent, Canterbury, Kent CT2 7NT, UK

² RJM International, Parchment St, Winchester SO23 8AT, UK

Rapid growth in electricity generation from intermittent renewables has resulted in increasing demand in conventional fossil-fuel power stations for plant flexibility, load balancing and fuel flexibility. This has led to new challenges in plant monitoring and control, particularly securing combustion stability for optimizing combustion process in terms of furnace safety, fuel efficiency and pollutant emissions. An unstable combustion process can cause many problems including furnace vibration, non-uniform thermal distribution in the furnace, high pollutant emissions and unburnt carbon in the flue gas. The stability of burners should therefore be continuously monitored and maintained for the improved overall performance of the furnace. A study is carried out to investigate the burner stability based on flame imaging and data fusion techniques. Experiments were carried out on a 915 MW_{th} coal-fired power station. A bespoke flame imaging system (Fig. 1) was employed to acquire flame images from 16 individual burners (4 mills each with 4 burners) with a frame rate up to 200 frames per second. The characteristic parameters of the flame, including temperature, non-uniformity, entropy, oscillation frequency and colour characteristics (hue, saturation and intensity), are computed. The relationship between the flame characteristics and burner inputs and flue gas emissions (e.g., NO_x) is quantified. Stability index is then introduced as an indicator of the stability of individual burner. Fig. 2 illustrates typical flame images for different burners. Detailed test results and analysis will be presented at the conference.




Fig. 1 Overview of the flame imaging system




Fig. 2 Flame images of 16 burners

Keywords: coal-fired boiler, flame, burner condition, combustion stability, digital imaging, image processing.

Acknowledgement: The authors wish to acknowledge Innovate UK for providing a grant (Project No: 132206) in aid of this research.

* Corresponding author: e-mail: m.hossain@kent.ac.uk