



# Kent Academic Repository

Xiaojing, Bai, Lu, Gang, Hossain, Md. Moinul, Szuhánszki, Janos, Daood, Sheraz, Yan, Yong, Nimmo, W and Pourkashanian, M (2016) *Multi-mode Combustion Process Monitoring through Flame Imaging and Soft-computing*. In: 11th European Conference on Coal Research and its Applications, 5-7 Sept 2016, the University of Sheffield, Sheffield, UK. (Unpublished)

## Downloaded from

<https://kar.kent.ac.uk/43235/> The University of Kent's Academic Repository KAR

## The version of record is available from

<http://www.coalresearchforum.org/conference.html>

## This document version

Presentation

## DOI for this version

## Licence for this version

UNSPECIFIED

## Additional information

## Versions of research works

### Versions of Record

If this version is the version of record, it is the same as the published version available on the publisher's web site. Cite as the published version.

### Author Accepted Manuscripts

If this document is identified as the Author Accepted Manuscript it is the version after peer review but before type setting, copy editing or publisher branding. Cite as Surname, Initial. (Year) 'Title of article'. To be published in *Title of Journal*, Volume and issue numbers [peer-reviewed accepted version]. Available at: DOI or URL (Accessed: date).

## Enquiries

If you have questions about this document contact [ResearchSupport@kent.ac.uk](mailto:ResearchSupport@kent.ac.uk). Please include the URL of the record in KAR. If you believe that your, or a third party's rights have been compromised through this document please see our [Take Down policy](https://www.kent.ac.uk/guides/kar-the-kent-academic-repository#policies) (available from <https://www.kent.ac.uk/guides/kar-the-kent-academic-repository#policies>).

# Multi-mode Combustion Process Monitoring through Flame Imaging and Soft-computing

X. Bai<sup>1</sup>, \*G. Lu<sup>1</sup>, M.M.Hossain<sup>1</sup>, J. Szuhánszki<sup>2</sup>, S. S. Daood<sup>2</sup>, Y. Yan<sup>1</sup>,  
W. Nimmo<sup>2</sup>, M. Pourkashanian<sup>2</sup>

<sup>1</sup>. School of Engineering and Digital Arts, University of Kent, Canterbury, Kent CT2 7NT, UK

<sup>2</sup>. Energy Engineering Group, Department of Mechanical Engineering,  
University of Sheffield, Sheffield S10 2TN, UK

## *Abstract for poster presentation*

Reliable monitoring and diagnosis of combustion stability in combustion systems such as fossil-fuel fired boilers, gas turbines and combustion engines are crucial to maintain the system safety, combustion efficiency and low emissions, particularly under variable operation conditions. Considerable efforts have thus been made in developing techniques for online monitoring and diagnosis of the stability of a combustion process. Among those, flame imaging conjoined with image processing and soft computing techniques has been paid much attention for both laboratorial and industrial applications. Some imaging and soft computing techniques have been proposed for combustion state monitoring, but most of them can only detect a single-mode condition. However, modern combustion systems often operate under variable conditions (i.e., multi-mode process). Due to the dynamic nature of the combustion process, single-mode monitoring methods often mistakenly determine some normal combustion behaviours as abnormal ones. The recent trend of using a variety of fuels, including low quality coals, coal blends, and co-firing biomass and coal, has further deteriorated this issue.

In this study, a method based on flame imaging and soft-computing techniques for multi-mode combustion process monitoring is proposed. Flame images are acquired using a flame imaging system. Mean intensity values of RGB image components and texture descriptors are extracted and computed from the grey-level co-occurrence matrix. Such features are then used as inputs to a combined PCA-KSVM (principle component analysis-kernel support vector machine) model for multi-mode process monitoring. In this method, the PCA serves for eliminating the impact of noise and instabilities on the mode recognition. The KSVM identifies the combustion mode by using the scores of the features in the principle component subspace. Finally, two multivariate statistic indices,  $T^2$  and SPE, are computed and used to assess the stabilities of the combustion process. The proposed approach has been examined by using flame images obtained on the UKCCSRC PACT 250kW PF (pulverised fuel) test rig under different operation conditions (e.g., variations in the primary air and secondary-territory air split). Test results have shown that the computed image features represent well the dynamic behaviours of the flame, and that the PCA-KSVM model has outperformed conventional methods in monitoring the multi-mode combustion process.

*Keywords:* pulverised fuel, flame imaging, monitoring, multi-mode process, flame stability, principle component analysis, kernel support vector machine

\* Corresponding author:

e-mail: [g.lu@kent.ac.uk](mailto:g.lu@kent.ac.uk)

Tel: +44 1277823706, fax. +44 1277456084